



WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle)

☒ Construction

☐ Decommission ORIGINAL INSTALLATION

Notice of Intent Number

PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal
☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other

TYPE OF WORK: Owner's number of well (if more than one) _____
☒ New well ☐ Reconditioned Method: ☐ Dug ☐ Bored ☐ Driven
☐ Deepened ☒ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 72 ft.
 Depth of completed well 72 ft.

CONSTRUCTION DETAILS
 Casing ☒ Diam. 6 from +1.5 ft. to 67 ft.
 Installed: ☐ Liner installed _____ Diam. from _____ ft. to _____ ft.
☐ Threaded _____ Diam. From _____ ft. to _____ ft.

Perforations: ☐ Yes ☒ No
 Type of perforator used _____
 SIZE of perfs _____ in. by _____ in. and no. of perfs _____ from _____ ft. to _____ ft.

Screens: ☒ Yes ☐ No ☒ K-Pac Location 66
 Manufacturer's Name _____
 Type STAINLESS Model No. TELE _____
 Diam 6 Slot size 12 from 67 ft. to 72 ft.
 Diam. Slot size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: ☐ Yes ☒ No Size of gravel/sand _____
 Materials placed from _____ ft. to _____ ft.

Surface Seal: ☒ Yes ☐ No To what depth? 18 ft.
 Material used in seal BENTONITE 3/8 CHIPS
 Did any strata contain unusable water? ☐ Yes ☒ No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____
 Type _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level 40 ft.
 Static level 43 ft. below top of well Date 5/24/13
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? ☐ Yes ☒ No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____

 Date of test _____
 Bailer test 10 gal./min. with 10 ft. drawdown after 2 hrs.
 Airstest _____ gal./min. with stem set at _____ ft. for _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? ☐ Yes ☒ No

CURRENT

Notice of Intent No.

W 360561

Unique Ecology Well ID Tag No

BHN 467

Water Right Permit No.

Property Owner Name Mc Knight

Well Street Address Green Rd

City Oak Harbor

County

ISLAND

Location NW 1/4 1/4 of the NW 1/4 Sec 23 Twn 33 R 2 EWM ☒
 (s, t, r Still REQUIRED) Or WWM ☐

Lat/Long

Lat Deg

Lat Min/Sec

Long Deg

Long Min/Sec

Tax Parcel S6559-00-00008-0

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

Matireal	FROM	TO
Top soil	0	1
Brown sandy clay	1	8
Gravelly clay	8	28
Sandy clay	28	50
Silty sand	50	59
Brown sand with water	59	72

WELL SITE MEETS ALL SET BACKS

REQUIRMENTS UNDER ICC 8.09

BASED ON INFORMATION FROM OWNER

RECEIVED

JUL 15 2013

DEPT OF ECOLOGY

Start date 5/22/13

Completed Date 5/24/13

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee Name (Print) Gerlof Boonstra

Drilling Company WHIDBEY WELL DRILLERS

Driller/Engineer/Trainee Signature

Address 716 Holbrook Rd

Driller or trainee License No. 0038

City, State, Zip Coupeville, WA, 98239

IF TRAINEE: Driller's License No.

Contractor's

Driller's Signature:

Registration No. WHIDBWD921 RS Date 7/15/13